

# CITY OF NEWTON, MASSACHUSETTS

## PURCHASING DEPARTMENT

[purchasing@newtonma.gov](mailto:purchasing@newtonma.gov)

Fax (617) 796-1227

August 20, 2012

## ADDENDUM #1

### INVITATION FOR BID #13-14

### SUPPLY & INSTALL SEWERAGE GRINDER AT THE QUINOBEQUIN ROAD PUMP STATION

THIS ADDENDUM IS TO: **Answer the following Items/Questions:**

The following are comments from JWC, the grinder manufacturer identified in the specification. As the authorized representative for JWC, we are formally requesting the following changes/clarifications to the spec:

Q1. Pg 117:

2.01 - In section 2.03 H. MOTORS are plural Please change Model No. CDD3216AD change to CDD3216XDM-2.0 for three motors or CDD3216XDS-2.0 for single motor.

2.03 – B. The sewage grinder “Frame” shall be..... 316 stainless steel. The material of the grinder is in section 2.03 J. Ductile iron

**A1. Revise Section 2.03 H to “Sewerage Grinder motor Model No. CDD3216XDS-2.0 shall be Submersible and explosion proof, UL listed for a class 1 Group “D” hazardous environment, premium energy efficient type, 1725 RPM, 60 Hz, 3-phase, 460V, +/-10%, TEXP, 1.15 service factor.**

**Remove “(316 stainless steel)” from section 2.03-B**

Q2. Pg 118

2.03 D. 1 – Please change AISI 4130 to AISI 8620 & 43-48 Rockwell “C” to 60-65 Rockwell “C”

2.03 E. 2 – Please advise which screen drums are required; coil or perforated both are listed?

**A2. In section 2.03 D-1 change “AISI 4130” to “AISI 8620” and “43-48 Rockwell “C” to “60-65 Rockwell “C”**

**In section 2.03.2 remove “or perforated plate” the city is requiring a “coil configuration”**

All other terms and conditions of this bid remain unchanged.

**PLEASE ENSURE THAT YOU ACKNOWLEDGE THIS ADDENDUM ON YOUR BID FORM.**

Thank you.

*Purchasing Department*